Autotrol Performa™Cv

Conditioner/Filter

Water Control System

Installation, Operation and Maintenance Manual

This s stem installed b:	

Table of Contents

1.0 Performa CV S stem	
1.1 Specifications	
1.2 Installation	
1.4 Disinfection of Water Conditioners	
1.4 Distillection of water Conditioners	0
2.0 Performa Cv 962 Control	0
2.1 Introduction to the Performa CV Conditioner and Filter S stems	
2.2 Programming and Application	
2.3 Conditioner Programming Tables	
3	
3.0 Performa Cv Filter Valve and Controls, 962F, 962FTC, 942F	18
3.1 Programming and Application	
3.2 E planation of Parameter Values for the 962 Single and Parallel Tank Controls	
4.0 Performa Cv Performance Charts and Graphs	27
4.1 General Specification	
4.2 Injector Curves	
4.3 Performa Cv Conditioner Performance Data	31
5.0 Performa Cv Service and Troubleshooting	
5.1 Historical Data	
5.2 Preventative Maintenance	
5.3 Removing the Valve Assembl for Servicing	
5.4 Removing the Control	
5.6 Valve Disc Principle of Operation.	
5.7 Performa Cv Conditioner Flo Diagrams	
5.8 Performa Cv Filter Flo Diagrams	
5.9 Troubleshooting	
6.0 Performa Cv Parts	44
6.1 Valve Component E ploded Vie	
6.2 Parts List	45
6.3 Performa Cv Controls	46

1.0 Performa Cv System

1.1 Specifications

1.1.1 Performa Cv Conditioner

Flow Rates (Valve Only) Service @ 15 psi (1.03 bar)	
Control Configurations 962 Microprocessor Demand System and 962 Electronic Timec Back ash Brine Slo rinse Fast rinse E ternal Brine Valve Required - Timed Fill	
Valve Connections/Dimensions Tank Thread	•

1.1.2 Performa Cv Filter Specifications

See Section 4.1 for specification dra ings.

Flow Rates (Valve Only)	
Service @ 15 psi (1.03 bar) drop	
Back ash (Filter) @ 25 psi (1.72 bar) drop	
Service	
Back ash Filter	•
544K 46H 116H 111H 111H 111H 111H 111H 11H 11H	(iv = 0.76)
Control Operation	
942F Mechanical Clock Timer - 7 Day or 12 Day	
Back ash	8-30 minutes
Fi ed Fast Rinse	
962F Microprocessor Demand	
Back ash	4 to 60 minutes
Fast Rinse	
962 FTC Electronic Time Clock	
Back ash	4 to 60 minutes
Fast Rinse	
Interval Regeneration	Da of the Week Regeneration
Valve Connections/Dimensions	
Tank Thread	2-1/2 inches - 8, male
Inlet/Outlet	1-3/4 inches - 12 UNC-2A, male
Drain Line	3/4-inch NPT, male
Brine Line	3/8-inch NPT, male
Distributor Tube O.D	1 050 inches (27 mm)
Distributor Tube Length	
Distributor Tube Length	
Distributor Tube Length	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control)	1/2 inches (13 mm 13 mm) above top of tank Glass-filled Plastic Compounded for cold ater 4.5 lbs (2.0 kg)
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output	1/2 inches (13 mm 13 mm) above top of tank Glass-filled Plastic Compounded for cold ater 4.5 lbs (2.0 kg) 12VAC 400 mA (4.6 vA)
Operating Valve Bod Rubber Components Weight (Valve ith Control)	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input Operating Pressure	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature.	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature.	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input Operating Pressure Water Temperature. Options B pass Valve, Model 1265	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input Operating Pressure Water Temperature Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits:	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature. Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits: Copper, S eat Tube Adapter	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature. Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits: Copper, S eat Tube Adapter CPVC, Solvent Weld Tube Adapter	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature. Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits: Copper, S eat Tube Adapter CPVC, Solvent Weld Tube Adapter Plastic NPT or BSPT Pipe Adapter	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature. Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits: Copper, S eat Tube Adapter CPVC, Solvent Weld Tube Adapter	1/2 inches (13 mm 13 mm) above top of tank
Operating Valve Bod Rubber Components Weight (Valve ith Control) Transformer Output Transformer Input. Operating Pressure Water Temperature. Options B pass Valve, Model 1265 B pass Inlet/Outlet Fitting Kits: Copper, S eat Tube Adapter CPVC, Solvent Weld Tube Adapter Plastic NPT or BSPT Pipe Adapter	1/2 inches (13 mm 13 mm) above top of tank

4

1.2 Installation

All plumbing and electrical connections must conform to local codes.

Inspect unit carefull for carrier shortage or shipping damage.

Location Selection

- 1. The distance bet een the unit and a drain should be as short as possible.
- 2. If it is likel that supplementar ater treatment equipment ill be required, make certain adequate additional space is available.
- 3. Since salt must be added periodical to the brine tank, the location should be easil accessible.
- 4. Do not install an unit closer to a ater heater than a total run of 10 feet (3 m) of piping bet een the outlet of the conditioner and the inlet to the heater. Water heaters can sometimes overheat to the e tent the ill transmit heat back do n the cold pipe into the unit control valve.

Hot ater can severel damage the conditioner. A 10-foot (3-m) total pipe run, including bends, elbo s, etc., is a reasonable distance to help prevent this possibilit. A positive a to prevent hot ater flo ing from heat source to the conditioner, in the event of a negative pressure situation, is to install a check valve in the soft ater piping from the conditioner. If a check valve is installed, make certain the water heating unit is equipped with a properly rated temperature and pressure safety relief valve. Also, be certain that local codes are not violated.

- Do not locate unit here it or its connections (including the drain and overflo lines) ill ever be subjected to room temperatures under 34°F (1°C) or over 120°F (49°C).
- 6. Do not install unit near acid or acid fumes.
- 7. The use of resin cleaners in an unvented enclosure is not recommended.

Water Line Connection

The installation of a b pass valve s stem is recommended to provide for occasions hen the ater conditioner must be b passed for hard ater or for servicing.

The most common b pass s stems are the Autotrol Series 1265 b pass valve (Figure 1.1) and plumbed-in globe valves (Figure 1.2). Though both are similar in function, the Autotrol Series 1265 b pass offers simplicit and ease of operation.

Not in Bypass




Figure 1.1 - Autotrol Series 1265 B pass Valve

Figure 1.2 - T pical Globe Valve B pass S stem


Drain Line Connection

Note: Standard commercial practices are e pressed here. Local codes ma require changes to the follo ing suggestions.

- 1. Ideall located, the unit ill be above and not more than 20 feet (6.1 m) from the drain. For such installations, using an appropriate adapter fitting, connect 1/2-inch (1.3-cm) plastic tubing to the drain line connection of the control valve.
- If the back ash flo rate e ceeds 5 gpm (22.7 Lpm) or if the unit is located more than 20 feet (6.1 m) from drain, use 3/4-inch (1.9-cm) tubing for runs up to 40 feet (12.2 m). Also, purchase appropriate fitting to connect the 3/4-inch tubing to the 3/4-inch NPT drain connection.
- 3. If the unit is located here the drain line must be elevated, ou ma elevate the line up to 6 feet (1.8 m) providing the run does not e ceed 15 feet (4.6 m) and ater pressure at conditioner is not less than 40 psi (2.76 bar). You ma elevate an additional 2 feet (61 cm) for each additional 10 psi (0.69 bar).

- 4. Where the drain line is elevated but empties into a drain belo the level of the control valve, form a 7-inch (18-cm) loop at the far end of the line so that the bottom of the loop is level ith the drain line connection. This ill provide an adequate siphon trap.
- 5. Where the drain empties into an overhead se er line, a sink-t pe trap must be used.

IMPORTANT: Never insert drain line into a drain, se er line or trap. Al a s allo an air gap bet een the drain line and the aste ater to prevent the possibilit of se age being back-siphoned into the conditioner.



Note: Standard commercial practices have been e pressed here. Local codes ma require changes to these suggestions.

Brine Line Connection

It ill be necessar to install the brine line for a Performa Cv conditioner to the brine fitting on the valve (3/8-inch NPT).

Be sure all fittings and connections are tight.

Overflow Line Connection

In the absence of a safet overflo and in the event of a malfunction, the BRINE TANK OVERFLOW ill direct overflo "to the drain instead of spilling on the floor here it could cause considerable damage. This fitting should be on the side of the cabinet or brine tank.

To connect overflo , locate hole on side of brine tank. Insert overflo fitting (not supplied) into tank and tighten ith plastic thumb nut and gasket as sho n (Figure 1.4). Attach length of 1/2-inch (1.3-cm) I.D. tubing (not supplied) to fitting and run to drain. Do not elevate overflo line higher than 3 inches (7.6 cm) belo bottom of overflo fitting. Do not tie into drain line of control unit. Overflo line must be a direct, separate line from overflo fitting to drain, se er or tub. Allo an air gap as per drain line instructions (Figure 1.3).




Figure 1.4

Battery Back-Up

All 962 famil controls are batter backup capable. A 9-volt rechargeable batter is available from Osmonics, P/N 1075768. The batter is a VARTA, TYPE V7/8H (AccuPlus Nickle H dride Ni-mh 9v 150 mAH, No. 5522). A standard non-rechargeable batter is an option for backup but needs to be replaced periodicall, Figure 1.5.

Figure 1.5

1.3 Placing Performa Cv Conditioner/Filter into Operation

After all previous steps have been completed, the unit is read to be placed into operation. Follo these steps carefull.

 Remove control valve cover b first depressing the plastic clips from the front of the cover. Pull front of cover up.

Note: The follo ing steps ill require turning the c cle indicator to various positions. Manuall rotate the camshaft **COUNTERCLOCKWISE** onl until c cle indicator points to desired position. (See manual regeneration sections for each control's manual operation.)

- 2. Rotate c cle indicator **COUNTERCLOCKWISE** until it points directl to the ord **BACKWASH**.
- 3. Fill media tank ith ater.
 - a. With ater suppl off, place the b pass valve(s) into the service" position.
 - b. Open ater suppl valve ver slo I to appro imatel the 1/4 open position.

IMPORTANT: If opened too rapidl or too far, media ma be lost. In the 1/4 open position, ou should hear air escaping slo 1 from the drain line.

Conditioner

- a. When all of the air has been purged from the tank (ater begins to flo steadil from the drain), open the main suppl valve all the a .
- b. Allo ater to run to drain until clear.
- c. Turn off ater suppl and let the unit stand for about five minutes. This ill allo all trapped air to escape from the tank.
- 4. Add ater to brine tank (initial fill).
 With a bucket or hose, add appro imatel 4 gallons (15 liters) of ater to brine tank. If the tank has a salt platform above the bottom of the tank, add ater until the level is appro imatel
- 5. Place the conditioner into operation.

1 inch (25 mm) above the platform.

- a. With the ater suppl valve completel open, carefull advance the c cle indicator COUNTERCLOCKWISE to the center of the BRINE REFILL position. Hold at this position until ater starts to flo through the brine line into the brine tank. Do not run for more than to minutes.
- Advance the c cle indicator
 COUNTERCLOCKWISE until it points to the center of the BRINE/SLOW RINSE position.

- c. With the conditioner in this position, check to see if ater is being dra n from the brine tank. The ater level in the brine tank ill recede ver slo I. Observe ater level for at least three minutes. If the ater level does not recede, or if it goes up, reference the **Troubleshooting** section.
- d. Advance the c cle indicator
 COUNTERCLOCKWISE to the
 REGENERATION COMPLETE position and run
 ater from a nearb faucet until the ater is
 clear and soft.

Filter

All filter medias e cept carbon:

- a. After the air has been purged from the tank (ater begins to flo steadil from the drain) open the main suppl all the a . Back ash media for a minimum of 15 minutes or longer if necessar . Water running to the drain should be clear.
 - Carbon media should be allo ed to soak for a minimum of 12 hours to allo air bubbles to escape prior to back ashing.
- After the back ash is complete plug in control and allo it to advance to BACKWASH COMPLETE.

Electrical Connection

100 VAC, 115 VAC, and 230 VAC units: Remove t ist tie from the po er cord and e tend cord to its full length. Make sure po er source matches the rating printed on the control. Be certain a all s itch does not control the outlet.

12 VAC: Connect the plug of the transformer (supplied) secondar cable to the mating socket at the rear or bottom of the timer housing. Be certain the transformer is secure and is plugged into a po er source of correct voltage that is not controlled b a all s itch.

1.4 Disinfection of Water Conditioners

The materials of construction of the modern ater conditioner ill not support bacterial gro th, nor ill these materials contaminate a ater suppl . Ho ever, the normal conditions e isting during shipping, storage and installation indicate the advisabilit of disinfecting a conditioner after installation, before the conditioner is used to treat potable ater. In addition, during normal use, a conditioner ma become fouled ith organic matter or in some cases ith bacteria from the ater suppl .

Thus ever conditioner should be disinfected after installation, some ill require periodic disinfection during their normal life, and in a fe cases disinfection ith ever regeneration ould be recommended.

Depending upon the conditions of use, the st le of conditioner, the t pe of ion e changer, and the disinfectant available, a choice can be made among the follo ing methods.

Sodium or Calcium Hypochlorite

Application

These materials are satisfactor for use ith pol st rene resins, s nthetic gel zeolite, greensand and bentonites.

5.25% Sodium Hypochlorite

These solutions are available under trade names such as Cloro Bleach*. If stronger solutions are used, such as those sold for commercial laundries, adjust the dosage accordingl .

1. Dosage

- Pol st rene resin: 1.2 fluid ounces per cubic foot
- Non-resinous e changers: 0.8 fluid ounce per cubic foot.

2. Brine tank conditioners

- a. Back ash the conditioner and add the required amount of h pochlorite solution to the brine ell of the brine tank. (The brine tank should have ater in it to permit the solution to be carried into the conditioner.)
- b. Proceed ith the normal regeneration.

Calcium Hypochlorite

Calcium h pochlorite, 70% available chlorine, is available in several forms including tablets and granules. These solid materials ma be used directl ithout dissolving before use.

1. Dosage

a. T o grains (appro imatel 0.1 ounce) per cubic foot.

2. Brine tank conditioners

- a. Back ash the conditioner and add the required amount of h pochlorite to the brine ell of the brine tank. (The brine tank should have ater in it to permit the chlorine solution to be carried into the conditioner.)
- b. Proceed ith the normal regeneration.

^{*}Cloro Bleach is a trademark of the Cloro Compan .

2.2 Programming and Application

This section covers all aspects of programming the 962 control.

Note that some parameters have a single unit of measure option such as the Rinse Time hich is onl entered in minutes. Other parameters have dual units such as Salt Amount hich can be entered in pounds or kilograms. To select hich units are active, look for a comment in the NOTES column of Table 2.1 and Table 2.4. It ill reference another parameter that selects hich units are active. For e ample, Parameter P12 (Table 2.4) selects U.S. units if it is set to "0" and metric if it is set to "1."

Level I Parameters (Table 2.1)

Level I Parameters are identified as those that have an LED indicator on the front panel. The green indicator illuminates ner to the name of the active control setting. The end user has access to all of these parameters. In general, pressing the **DOWN ARROW** (\downarrow) button displa s the Level I Parameters in the folloring order:

Time of Da Time of Regeneration Hardness Salt Amount Capacit

If ou continue to press the **DOWN ARROW** (\downarrow) button, the parameters start over ith Time of Da . Pressing the **UP ARROW** (\uparrow) button displa s the parameters in reverse order. Refer to Table 2.1 for a description of these parameters and the available ranges for each parameter.

Press the **SET** button and the far right number on the displa starts flashing. If ou ant to change this number, press the **UP ARROW** (\uparrow) button to increase the number or the **DOWN ARROW** (\downarrow) button to decrease the number. To skip the number ithout changing, press the **LEFT ARROW** (\leftarrow) button. When ou reach the far left digit, pressing the **LEFT ARROW** (\leftarrow) button ill return ou to the far right digit.

Note: If ou press and hold either the **UP ARROW** (\uparrow) button or the **DOWN ARROW** (\downarrow) button for more than one second, the flashing number ill increment or decrement at the rate of 10 counts per second.

When the number is correct, press the **LEFT ARROW** (\leftarrow) button. The first number stops flashing and the ne t number starts flashing. You can onl change the flashing number. Continue changing numbers until ou reach the desired setting. Press the **SET** button. The numbers stop flashing and the control accepts the ne setting. After appro imatel 30 seconds, the control starts alternating the displa bet een Time of Da and Capacit .

Note: If a beep sounds, the ne setting is not accepted because it as outside the allo able range. The old value ill be displa ed.

Day of Week/Time of Day

Press the **SET** button. The displa ill sho the Time of Da ith the minutes digit blinking. If ou ant to change this number, press the **UP ARROW** (\uparrow) button to increase the number or the **DOWN ARROW** (\downarrow) button to decrease the number. To skip the number ithout changing, press the **LEFT ARROW** (\leftarrow) button.

Salt Amount

Salt Amount is the ne t value displa ed. The default value for Salt Amount is 6 pounds (2.7 kilograms) of salt; refer to Table 2.2 for suggested salt settings.

Note: This is the total amount of salt used for a regeneration, not pounds per cubic foot. If 6 pounds is not acceptable, press the **SET** button and change the numbers. If 6 pounds is acceptable, press the **DOWN ARROW** (\downarrow) button.

Capacity

Capacit is the ne t value displa ed and is e pressed in kilograins (kilograms). Refer to Table 2.2 for the

Table 2.2 - Suggested Settings for P4, P5, P6, P7

P5 Capacity Setting	Resin Volume per Tank (liters)							
Kilograins (Kilograms)	3 ft ³ (85)	4 ft ³ (113)	5 ft ³ (142)	6 ft ³ (170)	7 ft ³ (198)			
		P4 Salt	Setting: Pounds (kg) of Salt				
60 (3.9)	18 (8.2)	-	-	-	-			
80 (5.2)	-	24 (10.9)	-	-	-			
84 (5.4)	30 (13.6)	-	-	-	-			
90 (5.8)	45 (20.4)	-	-	-	-			
100 (6.4)	-	-	30 (27.2)	-	-			
112 (7.2)	-	40 (18.1)	-	-	-			
120 (7.7)	-	60 (27.2)	-	36 (16.3)	-			
140 (9.0)	-	-	50 (22.7)	-	42 (19)			
150 (9.7)	-	-	75 (34)	-	-			
168 (10.8)	-	-	-	60 (27.2)	-			
180 (11.6)	-	-	-	90 (40.8)	-			
196 (12.7)	-	-	-	-	70 (31.8)			
210 (13.6)	-	-	-	-	105 (47.6)			

P6 Refill Setting: 14 inch tank = 74 (.74 gpm) 16 inch thru 21 inch tanks = 130 (1.39 gpm)

P7 Brine Draw Setting. All values are based on 50 psi (3.5 bar) inlet pressure. For pressure other than 50 psi refer to brine dra charts in Section 4.0.

Tank Diameter	Injector	Part Number	P7 equals	Color	
14 in (35.5 cm)	М	1055737	60	Bro n	
16 in (40.6 cm)	Q	1035739	80	Purple	
18 in (45.7 cm)	Q	1035739	80	Purple	
21 in (53.3 cm)	R	1035884	83	Dark Gre	

Level II Parameters (Table 2.4)

The Level II Parameters are P6 through P22 in Table 2.4. To access Level II Parameters, simultaneousl press and hold the **DOWN ARROW** (\downarrow) and **UP ARROW** (\uparrow) buttons for three seconds. A P" number ill displa .

Refer to Table 2.4 to find the parameter associated ith each P" number. Use the **UP ARROW** (\uparrow) button or the **DOWN ARROW** (\downarrow) button to move from one parameter to the ne t. The displa c cles through the P" numbers sho n in Table 2.1 and Table 2.4. When ou reach P22, the ne t P number ill go back to P1.

When the parameter number ou ant to change is on the displa , press the **LEFT ARROW** (\leftarrow) button to displa the data assigned to that parameter. Press the **SET** button and the far right number on the displa starts flashing. If ou ant to change this number, press the **UP ARROW** (\uparrow) button or the **DOWN ARROW** (\downarrow) button. To skip the number ithout changing, press the **LEFT ARROW** (\leftarrow) button. When the number is correct, press the **SET** button. The numbers stop flashing and the control accepts the ne setting. If a beep sounds, the ne setting as not accepted. Refer to Table 2.4 for allo able values for that parameter.

To change or vie other parameters, press the **LEFT ARROW** (\leftarrow) button to have the displa sho P" numbers. No use the **UP ARROW** (\uparrow) button or the do n arro (\downarrow) button to move to the parameter number ou ish to change.

To e it the Level II programming mode, simultaneousl press and hold the **DOWN ARROW** (\downarrow) and **UP ARROW** (\uparrow) buttons for three seconds, or ait 30 seconds ithout pressing a button. The control starts alternating the displa bet een Tank in Service, Flo Rate and Capacit .

Settings for all parameters can be ritten on the label provided ith the control. The label has an adhesive backing so it can be attached to the inside rear cover of this manual for future service reference.

Level II Programming

Parameter P6 is used b the control to calculate the Refill Time. Press **SET** button and enter a ne value. Refer to Table 2.2 for the correct value.

Parameter P7 is used b the control to calculate the brine dra time. Press the **SET** button and enter a ne value. Refer to Table 2.2 for the correct value. The control calculates the brine dra time using this value and the salt amount. The brine dra time is added to the Rinse Time (P10) to determine the total Brine Dra /Slo Rinse Time.

This control does not use Parameter P8. No entrol is needed for this parameter.

Parameter P12 selects the units of measure. Be sure that this is set to the correct value before entering an data for Parameters P3, P4 or P5.

Parameter P13 selects the clock displa mode. If the 12-hour mode is selected, a PM indicator is used. If the 24-hour mode is selected, the PM indicator is not used.

Parameter P15 has four allo able values. Values 0 or 1 ill cause the control to ait for Parameter P2, time of da of regeneration, to begin the regeneration. Values 2 or 3 ill cause the control to start the regeneration as soon as the capacit is e hausted.

When Parameter P15 selects a smart reserve t pe, 0 or 2, Parameter P16 is used to calculate the initial seven average dail ater usage values. The control multiplies the total capacit b the percentage entered for Parameter P16 and uses that value as the initial average dail usage for each da of the eek until ater usage establishes ne averages, refer to Reserve Options, page 15.

Parameter 17 must be programmed follo ing the appropriate programming table. Improper regenerations ill occur if P17 is set to an other number.

Parameter P18 allo s the installer to lock the Salt Amount and Capacit values so the cannot be changed. When Parameter 18 is set to 1, those to settings can onlobe vie edhen the control is in the Level II mode. The settings ill be skippedhen the control is in the Level I mode. When Parameter 18 is set to zero, the Salt Amount and Capacit can be vie ed and changed in either Level I or Level II.

Parameter P19 selects the flo sensor that is to be used ith the s stem. The factor preset value is 1 for a 1-inch turbine. The range is 1 - 4. 1 = Autotrol 1-inch turbine, 2 = Autotrol 2-inch turbine, 3 = user programmable K-factor, 4 = user programmable pulse equivalent. The K-factors or pulse equivalents for individual meters should be supplied b the respective meter manufacturer.

Parameter P20 is programmed onl if P19 = 3 or 4. P20 is here the factor supplied K-factor or pulse equivalent number is programmed.

Parameter P21 allo s the user to tell the control ho long a signal must be present at the remote

Parameter P22. Special codes are entered at the factor to program all of the pertinent P locations for specific controls; Metric for e ample. This parameter should never be changed b the end user.

Electronic Time Clock Operation

Programming automatic regeneration frequenc:

The Electronic Time Clock has to regeneration options: Interval Regeneration and Datof Week Regeneration.

To initiate an automatic regeneration one or both of the options must be chosen. The s stem ma also be regenerated manuall b pressing the Regeneration button for three seconds.

Interval Regeneration The Electronic Time Clock ma be programmed to regenerate in intervals of up to 30 da s. This feature is Parameter P14 Calendar Override (see Table 2.4). E ample: If 5 is programmed into P14 then the s stem ill regenerate ever five da s at the time programmed into P2.

Day of Week Regeneration The Electronic Time Clock ma be programmed to regenerate on a specific da or on specific da s of the eek. The instructions for this option are found in Table 2.3 on page 15.

Application

The Performa Cv 962 Conditioner and the Performa Cv 962F Filter ma be operated as a single, dual, or triple s stem.

Dual and Triplex Conditioners and Filters

The dual and triple s stems require a different cam than the cam that is used in the single unit s stems. The also require an interconnecting lock out cable. This allo s the unit that is in regeneration or back ash to signal the other units and prevents them from starting a regeneration or back ash until the first unit is finished. Dual and triple units should be plumbed in parallel ith each other. In a multi-unit s stem the back ash ater is supplied b the other unit or units in the s stem. In a dual filter s stem consideration must be given that the unit in service is able to satisf service requirements and be able to suppl sufficient back ash ater to the other filter hile it is in the back ash c cle. There is a selection guide, Table 4.6, in Section 4.0 to assist in qualif ing the choice of a dual or triple s stem. This selection guide is based on media back ash requirements and tank diameter.

A parallel kit must be purchased for multi-unit operation. The kit numbers are:

Dual Parallel Conditioner	P/N 1035923
Triple Parallel Conditioner	P/N 1035925
Dual Parallel Filter	P/N 1035924
Triple Parallel Filter	P/N 1035926

Kits include parallel operation cams and the proper interconnect cable.

Manual Start Regeneration

To force the control to perform a regeneration, press the **REGEN** button. This button is located on the front of the control. When ou press the **REGEN** button, the control performs a full regeneration of the conditioner.

If you press this button again more than one minute after regeneration begins, but before the regeneration is complete, a second regeneration will start when the first regeneration is finished. The displa ill freeze and onl sho the Regen Time Remaining as an indication that the second regeneration ill be performed. When the first regeneration is complete, the second one ill begin and the displa ill alternate bet een Flo and Regen Time Remaining.

Automatic Regeneration

Programming Day of the Week Regeneration/ Backwash

Enter Da of the Week Regeneration/back ash programming b depressing the **LEFT ARROW** (←) button and the **DOWN ARROW** (↓) button simultaneousl for 3 seconds. The da s are sho n as d1, d2, d3, etc., on the displa . Select the da s of the eek regeneration/back ash should occur. To activate that da , change the 0 to a 1. The programming mode ill be e ited if no ke s are pressed for 30 seconds. If this feature is used in conjunction ith calendar override the calender override timer ill be reset at the end of this regeneration/back ash.

Table 2.3 - Day of Week Regeneration/Backwash

#	Description of Parameter	Set as required 0 = No - 1 = yes	Notes			
d1	Sunda	As required	0 = no da of eek regeneration 1 = back ash this da			
d2	Monda	As required	0 = no da of eek regeneration 1 = back ash this da			
d3	Tuesda	As required	0 = no da of eek regeneration 1 = back ash this da			
d4	Wednesda	As required	0 = no da of eek regeneration 1 = back ash this da			
d5	Thursda	As required	0 = no da of eek regeneration 1 = back ash this da			
d6	Frida	As required	0 = no da of eek regeneration 1 = back ash this da			
d7	Saturda	As required	0 = no da of eek regeneration 1 = back ash this da			

Reserve Options

There are to to pes of reserve options for this control: fined reserve and smart reserve (historical atter usage pattern). The are selected ith Parameter P15.

Fixed Reserve

When fi ed reserve is selected, the control multiplies the ma imum s stem capacit b the percent value set in Parameter P16 and uses the result as a reserve.

Smart Reserve (water usage pattern)

The other reserve option allo s the control to adjust the reserve based upon the historical ater usage pattern of the s stem. The control keeps track of the ater usage for each da of the eek and uses that da 's average usage multiplied b 1.2 as the reserve for that da . Ever da at the Time of Regeneration, the control recalculates the da 's average ater usage. If less than 10% of a da 's average ater usage is used, the control ill not change the da 's average. If more than t ice the da 's average is used, the control uses the actual usage in the reserve calculation.

Since a ne installation has no histor of ater usage, the control multiplies the percent of capacit value set in Parameter P16 b the total s stem capacit to determine starting average for each da of the eek.

The factor set value for P16 is 30 hich means that 30% of the total s stem capacit is used for the starting average for each da.

Program Parameter P15 is also used to select hether the control aits until the Time of Regeneration set in Parameter P2 to start a regeneration, or if the control should begin a regeneration immediatel hen the capacit remaining is less than the reserve.

2.3 Conditioner Programming Tables

Table 2.4 - Level II Programming Performa Cv 962 Parallel Multi Tank or Single Tank Conditioner

Parameter	Description	Range of Values	Minimum Increment	Recommended Program Value	Units of Measure	Notes
P6	Refill controller	2-200	1	Selected from Table 2.2		This number tells the controller the rate of refill based on the refill control installed. Refill d ell time is calculated to refill the proper amount of ater into brine tank.
P7	Brine dra rate	2-200	1	Selected from Table 2.2		This number tells the controller the dra rate based on the injector size. The d ell time in the dra position is then calculated.
P9	Back ash time	4-60	1	14*	Minutes	*Ma be adjusted for application
P10	Slo Ri.5(e in F	Ri)-3(t90.8(c)o)-20.tto1	-85.3(468)-15	7 Ri043-30./F1 1	Tf31.0606 01.	636.0198 Tc0 T [(14)30.40*

Go to Section 3.2 for detailed e planation of the programming parameters on this page.

Table 2.5 - Programming Performa Cv 962TC Electronic Time Clock Conditioner

Parameter	Description	Range of Values	Minimum Increment	Recommended Program Value	Units of Measure	Notes
P1	Da of Week and Time of Da	(1-7) 1:00-12:59 AM or PM Metric (1-7) 0:00-23:59	(1 da) 1 Minute	Current Day and Time	Hour Minute	Range depends on value selected for P13. For da of eek SUN=1, MON=2, TUE=3, WED=4, THU=5, FRI=6, SAT=7. THIS IS THE LEFT MOST DIGIT ON THE DISPLAY
P2	Time of da to start regeneration	1:00-12:59 AM or PM 00:00-23:59		As required	Hour Minute	Range depends on value selected for P13
P3	As recommended			10		
P4	Salt amount	.5-125.0 .2-50.0	.5 .2	Selected from Table 2.2	Pounds Kilograms	
P5	Program as Recommended			10		
P6	Refill controller	2-200	1	Selected from Table 2.2		This number tells the controller the rate of refill based on the refill control installed. Refill d ell time is calculated to refill the proper amount of ater into brine tank.
P7	Brine dra rate	2-200	1	Selected from Table 2.2		This number tells the controller the dra rate based on the injector size. The s ell time in the dra position is then calculated.
P9	Back ash time	4-60	1	14*	Minutes	*Ma be adjusted for application
P10	Slo Rinse time	7-125	1	40*	Minutes	*Ma be adjusted for application. This time does not include the calculated brine dra time.
P11	Fast Rinse time	2-60	1	4*	Minutes	*Ma be adjusted for application
P12	Units of measure	0-1	1	0		0 = US, 1 = Metric
P13	Clock mode	0-1	1	0		0 = 12 hour clock, 1 = 24 hour clock
P14	Interval Regeneration Calendar override	0-30	1	0	Da s bet een regeneration	0 = no interval chosen - *Ma be adjusted for application.
P15	Does not appl for Timeclock operation			0		
P16	Does not appl for Timeclock operation			30		
P17	Operation t pe	3-4	1	6		6 = Single 962TC
P18	Salt Change Lock out	0-1	1	0		0 = none, 1 = Salt/Capacit change locked out
P19	Does not appl for Timeclock operation					
P20	Does not appl for Timeclock operation					
P21	Remote Regeneration S itch Dela	0-254	1	60	Seconds	Time remote s itch must be active to start a regeneration
P22	Factor Use Onl - DO NOT CHANGE			99		

Go to Section 3.2 for detailed e planation of the programming parameters on this page.

3.0 Performa Cv Filter Valve and Controls, 962F, 962FTC, 942F

3.1 Programming and Application

This section covers all aspects of programming the control.

Table 3.1 - Programming Performa Cv 962F Three Cycle Filter

			1			1
Parameter	Description	Range of Values	Minimum Increment	Recommended Program Value	Units of Measure	Notes
P1	Da of eek and time of da	(1-7) 1:00-12:59 AM or PM Metric (1-7) 0:00-23:59	(1 da) 1 Minute	Current Day and Time	Hour Minute	Range depends on value selected for P13. For da of eek SUN=1, MON=2, TUE=3, WED=4, THU=5, FRI=6, SAT=7,. THIS IS THE LEFT MOST DIGIT ON THE DISPLAY
P2	Time of da to start back ash	1:00-12:59 AM or PM 00:00-23:59		As required	Hour Minute	Range depends on value selected for P13
P3	Program as recommended			10 100	U.S. Metric	
P4	Program as recommended			0.5		
P5	Filter capacit			As required	U.S. Metric	Divide the volumetric capacit (gallons) of the filter b 100 and enter this number into P5. Divide the volumetric capacit (cubic meters) b 10 and enter this number into P5.
P6	Program as recommended			200		
P7	Program as recommended			200		
P9	Back ash time	7-60	1	14*	Minutes	*Ma be adjusted for application.
P10	Program as recommended			8		
P11	Fast Rinse time	9-60	1	9*	Minutes	*Ma be adjusted for application.
P12	Units of measure	0-1	1	0		0 = US, 1 = Metric 0 = 12 hour clock,
P13	Clock mode	0-1	1	0		1 = 24 hour clock
P14	Interval Regeneration	0-30	1	0	Da s	0 = no interval chosen - *Ma be adjusted for application
P15	Reserve T pe	0-3	1	0	For a detailed e planation go to E planation of Parameter Values" P2 on page 24.	0 = Smart Reserve, 1 = Fi ed Reserve, 2 = Smart Reserve ith Immediate Regeneration, 3 = Fi ed Reserve ith Immediate Regeneration.
P16	Fi ed reserve percentage	0-70	1	30		This number is used to establish initial Dail Average.
P17	Operation t pe	0-7	1	4		4 = Filter Performa Cv
P18	Salt Change Lock out	0-1	1	0		0 = none, 1 = Salt/Capacit change locked out
P19	Flo Sensor Select	1-4	1	1		1 = 1" Autotrol Turbine, 3 = User Defined K-factor, 2 = 2" Autotrol Turbine, 4 = User Defined Pulse Equivalent
P20	K-factor or Pulse Equivalent	0.01-255.0	0.01	0.01		Number used for Meter K-factor or Pulse Equivalent.
P21	Remote Regeneration S itch Dela	0-254	1	60	Seconds	Time remote s itch must be active to start a back ash
P22	Factor Use Onl - DO NOT CHANGE			99		

Go to Section 2.2 for detailed e planation of the programming parameters on this page.

Table 3.2 - Programming Performa Cv 962F Five Cycle Filter

Parameter Description Range of Minimum Values Increment Value Recommended Program Value Units of Weaam2ttls7

Go to Section 2.2 for detailed e planation of the programming parameters on this page.

Table 3.3 - Programming Performa Cv 962 TC <u>Electronic Time Clock Filter</u>

Parameter	Description	Range of Values	Minimum Increment	Recommended Program Value	Units of Measure	Notes
P1	Da of eek and time of da	(1-7) 1:00-12:59 AM or PM Metric (1-7) 0:00-23:59	(1 da) 1 Minute	Current Day and Time	Hour Minute	Range depends on value selected for P13. For da of eek SUN=1, MON=2, TUE=3,

Go to Section 2.2 for detailed e planation of the programming parameters on this page.

Electronic Time Clock Operation

To initiate an automatic back ash one or both of the follo ing options must be chosen. The s stem ma be back ashed manuall b pressing the Back ash button for three seconds.

Programming automatic regeneration frequenc:

The Electronic Time Clock has to regeneration options: Interval Regeneration and Da of Week Back ash.

Interval Backwash The Electronic Time Clock ma be programmed to regenerate at intervals up to 30 da s. This feature is also kno n as Calendar Override. It is located at P14. E ample: If 5 is programmed into P14 then the s stem ill back ash ever five da s at the time programmed into P2.

Day of Week Backwash The Electronic Time Clock ma be programmed to back ash on a specific da or specific da s of the eek. The instruction for this option is found in Table 2.3 on page 17.

Application

The Performa Cv 962 Conditioner and the Performa Cv 962F Filter ma be operated as a single, dual, or triple s stem.

Dual and Triplex Conditioners and Filters

The dual and triple s stems require a different cam than the cam that is used in the single unit s stems. The also require an interconnecting lock out cable. This allo s the unit that is in regeneration or back ash to signal the other units and prevents them from starting a regeneration or back ash until the first unit is finished. Dual and triple units should be plumbed in parallel ith each other. In a multi-unit s stem the back ash ater is supplied b the other unit or units in the s stem. In a

3.2 Mechanical

Series 942F Mechanical Control

The Series 942F mechanical control provides mechanical timeclock function for filter applications.




Figure 3.1

3.2.1 Settings

Setting the Time of Da , the Da s of Back ash and performing manual back ashing ith the 942F controls.

Setting the Time of Day

Rotate the Clock Dial **clockwise** until the pointer indicates the correct time of da . With the time of da set, the conditioner ill back ash at appro imatel 2:00 a.m. If it is desired to have the unit back ash at an earlier or later time, simpl offset the current time of da accordingl . For e ample, to have the unit back ash at 4:00 a.m., set the Clock Dial 2 hours later than the actual current time of da .

Note: Do not rotate the Calendar Cap by hand. The Clock Dial inde es the Calendar Cap dail . To manuall inde the Calendar Cap, rotate the Clock Dial clockwise one complete turn for ever da to be inde ed. Da pins should be in the out ard position during Clock Dial rotation to prevent an undesired back ash. Reset da pins hen completed.

Setting the Days of Backwash

Setting the da s that the conditioner ill back ash is accomplished in to simple steps:

- 1. Pull all of the da pins out ard.
- 2. Push in the da pin(s) for the da (s) on hich a back ash is desired.

NOTE: The NEXT DAY pin is noted on the control face. Pushing this pin ill insure a back ash the ne t da at appro imatel 2:00 a.m. since the Calendar Cap progresses in a clock ise direction, pushing the da pin immediatel follo ing the NEXT DAY pin counterclock ise ill insure a back ash occurs the follo ing da at appro imatel 2:00 a.m. This progression is noted on the control face as FUTURE DAYS".

Manual Backwash

E cessive ater usage or other service related issues ma create the need to manuall back ash the filter. This function is performed b rotating the Indicator Knob **COUNTERCLOCKWISE** to the START" position. Once in this position, the filter ill begin a back ash ithin a fe minutes. The normal schedule, established ith the pushed in da pins, ill not be disrupted b a manual back ash.

24 Hour Clock

The Performa Cv Series 942F control utilizes a 24 hour clock dial. This is t picall referred to as Militar Time". The hours of the da bet een 12:00 a.m. (midnight) and 12:00 p.m. (noon) are designated on the clock dial b the numbers 1 through 12, ith 1 being 1:00 a.m. The hours of the da bet een 12:00 p.m. (noon) and 12:00 a.m. (midnight) are designated on the clock dial b the numbers 13 through 24, ith 13 being 1:00 p.m. Be sure to set the correct time of da accordingl .

Adjusting the Backwash Setting

The Back ash Dial (Figure 3.2) controls the back ash time. With the Indicator Knob in the BACKWASH COMPLETE position, rotate the Back ash Dial counterclock ise at least one full turn to cancel out the current setting. A light clicking sound ill be replaced b a heavier clicking sound hen the previous setting is cancelled. Once the heavier clicking is heard, the ne setting ma be set b rotating the Back ash Dial to the desired setting. The numbers on the Back ash Dial represent MINUTES" of back ash time.




Figure 3.2 Back ash Complete

Table 3.4 - Cycle Times for 942F Control

Cycle	Time (Minutes)
Back ash	8 - 30
Purge	9

3.3 Explanation of Parameter Values for the 962 Single and Parallel Tank Controls

This section contains a detailed e planation of the programming parameters in the 962 electronic control.

Number

Description of Program Values Explanation

Number	Description of Program Values	Explanation
P5 page 12	Capacit of unit	Enter the capacit of the unit here, in kilograins (kilograms). For e ample, a 3 ft³ unit ith a resin capacit of 25,000 grains (1620 grams) per ft³, enter 75 here. (25,000 grains/ ft³) (3 ft³) = 75,000 grains = 75 kilograins. [(1620 grams/ ft³) (3 ft³) = 4860 grams = 4.86 kilograms]. Note: 15 lb/cu ft salting ields 30,000 grains/cu ft resin 10 lb/cu ft salting ields 25,000 grains/cu ft resin 6 lb/cu ft salting ields 20,000 grains/cu ft resin Reduced salting ields a reduced capacit 1 kilograin (1000 grains) = 0.0648 kilograms (64.8 grams)
P6 page 12	Refill control	Enter value from Table 2.1 - Suggested Settings on page 12 of manual. This value is the refill flo rate times 100, rounded to the ne thole number. For example, on a 16-inch tank, the refill control has a flo rate of 1.3 gpm. Enter 130 (1.3 gpm 100 = 130).
P7 page 12	Brine dra rate	Enter value from Table 2.1 - Suggested Settings on page 12 of manual. This is the injector dra rate times 100, rounded to the ne t hole number. For e ample, on a 16-inch tank, the injector has a dra rate of 0.8 gpm. Enter 80 (0.8 gpm 100 = 80).
P8	Not used	P8 is reserved for future use.
P9	Back ash time	Self e planator . Generall , 5 to 15 minutes or until ater runs clear or specific ater conservation needs are met.
P10	Slo rinse	Time, in minutes, to achieve adequate slo rinse volume for resin t pe used. Resin manufacturers recommend one to t o and one half bed volumes of slo rinse ater. The required amount of time is calculated using the injector performance curves provided in Section 4.0 of this manual.
		For e ample, assuming 4 cubic feet of resin and t o bed volumes of slo rinse ater for a 16 65, 50 psi inlet pressure, program 43 minutes in Parameter P10. (4 cubic feet) (7.5 gallons/cubic foot) 2 (bed volumes) = 60 gallons of slo rinse ater. A Q" injector is recommended for a 16-inch tank. From the Q" injector performance chart the nominal slo rinse rate is 1.4 gpm. 60 gallons divided b 1.4 gallons per minute equals 42.8 minutes. Round up to 43 minutes and enter in P10.
P11	Fast rinse	Time, in minutes, to achieve adequate fast rinse volume for resin t pe used. For e ample, for standard softening resin (lonac C-249), fast rinse at 30 gallons (0.11 m³) per cubic foot of resin. A unit ith 3 ft³ of resin ill require 90 gallons (0.34 m³) of ater to obtain the resin manufacturer's recommended fast rinse. (30 gal/ ft³ 3 ft³) = 90 gallons. (0.11 m³/ ft³ 3 ft³ = 0.34 m³). The fast rinse flo rate is controlled b the drain line flo control. For this e ample, assume a 5 gpm (1.14 m³/hr) drain line flo control. Enter 18 minutes in P10. (90 gallons/5 gpm) = 18 minutes (0.34 m³/1.14 m³/hr = 0.3 hr/ 60 min = 18 minutes).
P12	Units of measure	Self e planator . Enter 0 for U.S., enter 1 for metric.
P13	Clock mode	Self e planator . Enter 0 for 12-hour clock, enter 1 for 24-hour clock.
P14	Calendar override	0 = No calendar override. 1 - 30 = Ma imum number of da s bet een regeneration/back ash.
P15	Reserve t pe Immediate or dela regeneration	See P2. Not used in Alternating mode.
P16 ***	Fi ed Reserve capacit	If P15 is set at 1 or 3, enter the fi ed reserve capacit (in gallons) (m³) that the unit ill look for as e plained in sections P2 and P15 above. Not used in Alternating mode.
P17	Operation t pe	Self e planator . 3 = Single or parallel Conditioner or Tank; 4 = Single or Parallel Filter.

Number	Description of Program Values	Explanation
P18	Salt/capacit lockout	Allo s for the lock out of P4 and P5 so that NO unauthorized changes to the programmed values can be made.
P19	Flo Sensor Select	This parameter is used to select the flo sensor that is to be used ith the s stem. The factor -preset value is 1 for a 1-inch turbine. The range is 1 - 4. 1 = Autotrol 1-inch turbine, 2 = Autotrol 2-inch turbine, 3 = user programmable K-factor, 4 = user programmable pulse equivalent. The respective meter manufacturer should supple the K-factors or pulse equivalents for individual meters.
P20	K-factor or pulse equivalent	The range is 000.01 to 255.00 in 0.01 steps. Ho this number is used is defined b the values stored in P12 (units of measure) and P19 (flo sensor select). P12 is used to define gallons or liters (0 = gallons, 1 = liters). P19 is used to define K-factor or pulse equivalent (3 = K-factor, 4 = pulse equivalent). K-factor is defined as pulses per gallon or pulses per liter. Signet and Sea-Flo are to flo sensor manufacturers that publish a K-factor. The control can no use an flo sensor as long as the programmed K-factor is correct. The pulse equivalent is defined as gallons or liters per pulse. The control ill register 5 gallons of flo for ever pulse if P12 = 0, P19 = 4 and P20 = 5.00. Badger Meter is one manufacturer that uses a pulse equivalent. The control ill not sho flo rate if P19 = 4 (pulse equivalent). This is because pulses are accumulated over 10 seconds and flo rate is displa ed in gallons per minute. The control ill alternate bet een time of da and capacit remaining or regeneration time remaining during normal operation.
P21	Remote regeneration/ back ash s itch dela	This parameter is used to program the length of signal time required to initiate a regeneration/back ash using a differential pressure s itch or remote start button/contact. The range is 1 to 254 seconds in 1-second steps. The default is 60 seconds. A counter starts hen there is a closed dr contact (no voltage) to this input. A regeneration/back ash ill start hen the contacts remain closed for the programmed time. The counter ill reset to zero hen the contacts open for at least 0.02 seconds. The remote regeneration input cannot be used to perform a double manual regeneration. The remote regeneration input is ignored during a regeneration/back ash.
P22	Factor use onl	DO NOT CHANGE


^{*} The 962 controller functions in either a 12-hour or 24-hour clock mode. Programming P13 (clock mode) before P1 or P2 ill eliminate an confusion hen setting these parameters.

*** The calculated gallon amount loaded into the dail registers (L7 through L13) at START-UP, uses this percentage of capacit . E ample: 90,000 grains in P5 10 grains in P3, 90,000 / 10 = 9,000 gallon capacit , 9,000 .3 (30% in P16) = 2700 gallons, hich is loaded into L7 through L13, the dail averages. For this e ample, the smart reserve at START-UP, ould be 2700 gallon 1.2 (120% of the dail average) = 3240 gallon. This dail average ill change as actual ater usage information is gathered.

^{**} The 962 controller functions in either U.S. or metric units. Programming P12 (units of measure) before P3 or P4 ill eliminate an confusion hen setting these parameters.


4.0 Performa Cv Performance Charts and Graphs


4.1 General Specification





H drostatic Test Pressure
Working Pressure
Standard Electrical Rating
942F: 7 da or 12 da /24 hour 50 Hz 12 V transformer, 60 Hz 120 Vac or 12 V transformer
Electrical Cord (standard rating)
Pressure Tank Thread
Riser Pipe Diameter Required
Riser Pipe Length
Standard Connection
Optional Connections
3/4-inch BSPT, 1-inch BSPT, 1-inch NPT brass pipe adapters
3/4-inch, 1-inch, 1-1/4-inch, 25-mm CPVC tube adapters
Brine Line Connection
Drain Line Connection
Optional B pass Valve Rotating handles, full 1-inch porting, reinforced Plastic
Control Module, Tank Adapter
Rubber Goods
Program Clock (Timer) 942F: Available in 7- to 12-da English, German, French, Italian, Spanish, Japanese 962, 962F, 962FC, 962FTC: Available in English, German, French, Italian, Spanish, Japanese
Brine Refill Control0.74 and 1.3 GPM
E ternal Back ash Controllers


4.2 Injector Curves











4.3 Performa Cv Conditioner Performance Data

Table 4.1 - Performa Cv Injector Performance Chart

			Inject	ors L - R F	low Rate C	harts (gpn	n)			
PSI	L		М		N		Q		R	
	Draw	Rinse	Draw	Rinse	Draw	Rinse	Draw	Rinse	Draw	Rinse
20	0.26	0.4	0.3	0.5	0.4	0.65	0.4	0.9	0.45	1.2
30	0.3	0.45	0.4	0.55	0.45	0.75	0.5	0.95	0.5	1.3
60	0.5	0.6	0.6	0.8	0.75	1	0.82	1.4	0.9	1.75
80	0.6	0.65	0.7	0.85	0.8	1.1	0.9	1.6	1	2
100	0.6	0.76	0.7	0.9	0.8	1.6	0.95	1.8	1.1	2.2
			Inject	ors L - R F	low Rate C	harts (Lpn	n)			
Bar		L	ı	VI		N	(Q	ĺ	R
	Draw	Rinse	Draw	Rinse	Draw	Rinse	Draw	Rinse	Draw	Rinse
1.4	0.98	1.5	1.1	1.9	1.5	2.5	1.5	3.4	1.7	4.5
2.1	1.1	1.7	1.5	2.1	1.7	2.8	1.9	3.6	1.9	4.9
4.2	1.9	2.3	2.3	6	2.8	3.8	3.1	5.3	3.4	6.6
5.6	2.3	2.5	2.6	3.2	3	4.2	3.4	6	3.8	7.6
7	2.3	2.9	2.6	3.4	3	4.9	3.6	6.8	4.2	8.3

Table 4.2 - Service and Backwash Flow Performance Data

F	Flow vs Pressure Drop	o (gpm)	Flow vs Pressure Drop (Lpm)			
PSI	Service (Cv 6.5)	Backwash (Cv 4.0)	Bar	Service (Cv 6.5)	Backwash Cv 4.0)	
5	15	9	0.35	56	34	
10	20	13	0.7	76	49	
15	25	16	1	95	61	
20	29	18	1.4	109	68	
25	32	20	1.7	121	76	
30	35	22	2.1	132	83	

Table 4.3 - Recommended Drain Flow Controls (Backwash Anion and Cation Resin @ 55° F (12.7°C) Water Temperature

Tank Diameter Inches (mm)	Bed Area sq. ft.	Anion Resin @ 3 gpm/sq ft (m ³ h/sq ft)	Cation Resin @ 5 gpm/ sq ft (m ³ h/sq ft)
14 (35.6)	1.02	3 (.7)	5 (1.1)
16 (40.6)	1.38	4 (.9)	7 (1.5)
18 (45.7)	1.76	5 (1.1)	8 (1.8)
21 (53.3)	2.4	7 (1.5)	12 (2.7)

Table 4.4 - Performa Filter

Pressure Loss vs Flow (gpm)						
PSI	Service (Cv 6.5)	Backwash (Cv 5.0				
5	15	11				
10	20	16				
15	25	19				
20	29	22				
25	32	25				
30	35	27				
	Pressure Loss vs Flow (Lp	m)				
Bar	Service (Kv 5.6)	Backwash (Kv 5.8)				
0.35	56	42				
0.7	76	61				
1	95	72				
1.4	109	83				
1.7	121	95				
2.1	132	102				

Table 4.5 - Typical Backwash Flow Requirements for Various Filter Medias (based on 55° F (12.7°C) water temperature)

		GAC/CARBON FILT	TER-AG, CALCITE			
			GREENSAND			
			RM			
				SAND, MI	ULTI-MEDIA	
Tank Dia. inches (mm)	Bed Area sq. ft.		8 gpm/sq ft (Lpm/sq ft)	10 gpm/sq ft (Lpm/sq ft)	12 gpm/sq ft (Lpm/sq ft)	15 gpm/sq ft (Lpm/sq ft)
14 (35.6)	1.02	8 (30)	10 (38)	12 (45)	15 (57)	
16 (40.6)	1.38	11 (42)	13 (49)	16 (61)	20 (76)	
18 (45.7)	1.76	14 (53)	17 (64)	21 (79)	*26 (98)	
21 (53.3)	2.4	19 (72)	24 (91)	*29 (98)		
24 (60.9)	3.14	25 (95)				

^{*}Ma e ceed 25 psi or 1.72 bar pressure drop.

Table 4.6 - Performa Cv Filter Sizing Selection Guide for Dual Unit Filters.

		GAC/CARBON FILT	TER-AG, CALCITE			
			GREENSAND			
			В			
			SAND, M		IULTI-MEDIA	
Tank Dia. inches (mm)	Bed Area sq. ft.	8 gpm/sq ft (Lpm/sq ft)	10 gpm/sq ft (Lpm/sq ft)	12 gpm/sq ft (Lpm/sq ft)	15 gpm/sq ft (Lpm/sq ft)	
14 (35.6)	1.02	8 (30)	10 (38)	12 (45)	NR	
16 (40.6)	1.38	11 (42)	13 (49)	NR	NR	
18 (45.7)	1.76	*14 (53)	NR	NR	NR	
21 (53.3)	2.4	NR	NR	NR	NR	

^{*} Ma e ceed 25 psi or 1.72 bar pressure drop during back ash of second unit.

NR = Not Recommended. A flo control on the service outlet of each valve ma be required to insure proper back ash volume to back ashing unit.

5.2 Preventative Maintenance

Injector Screen and Injector

Inspect and clean brine tank and screen futer on end of brine pickup tube once a ear or hen sediment appears in the bottom of the brine tank.

Clean injector screen and injector on 🙀 a ear:

- 1. Unplug the all-mount transformer.
- 2. Shut off ater suppl or put b pass valve(s) into b pass position
- 3. Relieve s stem pressure b pening valve No. 7 (at rear) th a scre driver.
- 4. Using a scre priver, remove injector screen and injector cap (Figure 5.1).
- 5. Clean screen using a fine brush. Flush until clean.
- 6. Using a needle-nose plers, pull injector straight out.
- 7. Flush a er into the piector screen recess of the valve book to flush debris out through the injector recess.
- 8. Clean and lugh the njector.
- 9. Lubricate the O-rings on the injector, injector cap and injector screen ith silicone lubricant only!
- 10. Reinstall the injector injector cap and injector screen.

MPORTANT: Do not evertighten the plastic cap. Seat the cap lightly to position. Overtightening macause breakage of the plastic cap that manot be immediately evident.

- 11. Plug the / all mount transformer into outlet; reset clock if necessar.
- 2. Slo I/open ater supply valve or return by ssylvalve(s) to the service" position.

Water Meter Maintenance

The metering device used ith the 962 Cv demand controls ma require simple maintenance. In rare instances, the turbine heel of the ater meter can collect small particles of o idized iron, eventuall preventing the heel from turning.

- 1. Shut off the ater suppl or put the b pass valve(s) into the b pass position.
- 2. Relieve pressure b opening the Back ash Drain Valve (the seventh back from the control) ith a scre driver.
- 3. Loosen and remove the pipe/tube adapters or 265 b pass from the inlet and outlet of the valve bod .
- 4. Using a needle-nose pliers, remove the urbine from the outlet housing. Grasp one of the four vanes of the outer gland and pull straight out to remove turbine assembl from the outley of the valve (Figure 5.1).
- 5. Carefull remove the turble heel from the housing. Use a toothbrosh to light scrub the from off the magnet. Iron fulldup on the surfaces can be removed b soaking the heel in a mild sodium h drosulfite (such as RoVer*) solution for a fe minutes. Flugh thorough ith ater.
- 6. Carefull feinstall the turbine heel into the turbine cage busing. Make sure that the shaft of the heel seats into the bearing of the cage. Reassemble the turbine cage and check that the heel rotates freel.
- 7. Reinstall the turbine dage into the outlet of the valve.
- 8. Reinstall the pipe/tube adapters or 1267 b pass to the inlet and outlet of the valve.
- 9. Turn on the ater suppl or put the b pass valve (s) into the service position and purge the air out of the step.

To check for proper meter operation, open a do nstream faucet and observe the ater flo indication, blinking colon, on the control displa

*RoVer is a trademark of Hach Chemical Compan

Figure 5.h

e Valve Assembly for

r cord.

ppl or put b pass valve(s) into

nd ith scre driver, relieve tank ing open valve No. 7 (rear flapper) n (Figure 5.2).




Figure 5.2

a globe valve b pass, loosen and outlet, brine and drain lines from g the 1265 b pass, loosen and m b pass as ell as loosening and ne and drain lines.

rclock ise) and remove valve

ontrol valve, reverse the above

e Control

ng steps to remove the 960 ProSoft

nount transformer.

r suppl or put the b pass valve(s) ion.

cover b depressing the to tabs cover, Figure 5.3. Lift the front of move to e pose the valve bod.


Figure 5.3

4. Relieve s stem pressure b opening the Back ash Drain Valve (the seventh valve back from the control) ith a scre driver, Figure 5.4.

Figure 5.4

5. To remove the camshaft or to reinstall it, the arro on the rear of the cam shaft must be pointing at the line on the rear hoop" of the top plate. This occurs hen the c cle indicator is rotated to the refill position. Press do n on the back of the camshaft to disengage it from the rear hoop" of the top plate, Figure 5.5.


Slide the camshaft back to disengage it from the timer, Figure 5.6.



- 6. Disconnect the turbine probe from the turbine assembl .
- 7. Lift the control off the valve, Figure 5.7. To replace the control, reverse the above procedure. Note that the camshaft needs to be positioned correctl before it can be inserted into the back of the control. There is a locating arro on the camshaft. Position the arro on the top of the shaft and slide the camshaft into the control. Push up on the end of the camshaft, furthest from the timer, snapping it into place.


Figure 5.7

5.5 Identification of Control Valving




3 Brine/Slow Rinse Position

4 Fast Rinse Position




5.8 Performa Cv Filter Flow Diagrams

1 Backwash Position



2 Fast Rinse Position



5.9 Troubleshooting

The technolog upon hich the Autotrol Performa control valve is based is ell established and proven in service over man ears. Ho ever, should a problem or question arise regarding the operation of the s stem, the control can be serviced easil. For parts mentioned, refer to e ploded vie s in the **Replacement Parts** section of this manual.

IMPORTANT: Service procedures that require the ater pressure to be removed from the s stem are marked ith a ! after the possible cause. To remove ater pressure from the s stem, put the b pass valve or three-valve b pass into the b pass position and open the back ash drain valve (the seventh valve back from the control) ith a scre driver. Restore s stem ater pressure hen the service ork is completed.

Valve Troubleshooting

Problem	Possible Cause	Solution		
1. Control ill not dra brine.	a. Lo ater pressure.	a. Set pump to maintain 30 psi at conditioner.		
	b. Restricted drain line.	b. Remove restriction.		
	c. Injector plugged!	c. Clean injector and screen.		
	d. Injector defective !	d. Replace injector.		
	e. Valve (2 and/or 4) not closed.	e. Remove foreign matter from disc and check disc for closing b pushing in on stem. Replace if needed.		
	f. Damaged injector O-ring.	f. Replace injector O-ring.		
2. Brine tank overflo .	a. Brine valve (1) being held open.	 a. Manuall operate valve stem to flush a a obstruction. 		
	b. Uncontrolled brine refill flo rate!	b. Remove variable salt controller to clean.		
	 valve (3 or 4) not closed during brine dra causing refill. 	 Flush out foreign matter b holding disc open and manuall operating valve stem. 		
	d. Air leak in brine line.	 d. Check all connections in brine line for leaks. Refer to instructions. 		
3. S stem using more or less salt	a. Inaccurate setting.	a. Correct setting.		
than salt control is set for.	Foreign matter in controller causing incorrect flo rates!	 Remove variable salt controller and flush out foreign matter. Manuall position control to brine dra to clean controller (after so doing, position control to purge" to remove brine from tank). 		
	c. Defective controller.	c. Replace controller.		
4. Intermittent or irregular brine	a. Lo ater pressure.	a. Set pump to maintain 30 psi at conditioner.		
dra .	b. Defective injector!	b. Replace both injector and injector cap.		
5. No conditioned ater after	a. Unit did not regenerate.	a. Check for po er.		
regeneration.	b. No salt in brine tank.	b. Add salt.		
	c. Plugged injector!	c. Clean injector. Flush ith ater.		
6. Control back ashes at	a. Incorrect back ash controller used.	a. Replace ith correct size controller.		
e cessivel lo or high rate.	 Foreign matter affecting controller operation ! 	b. Remove controller and ball. Flush ith ater.		
Flo ing or dripping ater at drain or brine line after	 a. Drain valve (6 or 7) or brine valve (1) held open b foreign matter or particle. 	 a. Manuall operate valve stem to flush a a obstruction. 		
regeneration.	 b. Valve stem return spring on top plate eak. 	b. Replace spring.		

8. Hard ater leakage during servici atM [(8.4 - 2.78a9 TD0.0192 p)-3I.7(d)-m7(r)7(pD[(d)3-0.5(o)p19.6(b)30.4-15.7(a)-D[(d)3 b)30.4g018pingi-0.5(o)nlg.apastctml8)lv used

962 Control Troubleshooting

Alarms

The Model 962 continuousl monitors itself and sounds an alarm if it detects something rong. The alarm is a beep that is on for one second and then off for nine seconds.

When the alarm sounds, the displa sho s the letters Err" ith a number from 1 to 4. The table belo lists the Err numbers, a description of each error, the cause of the error, and the solutions. To silence the alarm, press an button on the control. If the error still e ists, the control ill go back to the alarm condition after 30 seconds.

Model 960 Alarms

Indication	Description	Cause	Solution	
Err1	Electronics Failure	Control settings need reprogramming.	Press an ke to load default values. Refer to Programming the Model 960 Control".	
Err2	Improper start of regeneration (limit s itch closed hen it should be open).	Valve camshaft has been manuall rotated during a regeneration. Valve camshaft has been manuall rotated out of regeneration complete" position. Fault motor. Fault s itch.	Press an ke to silence the alarm. (Note: Alarm automaticall clears at TIME OF REGEN".) The control ill turn the motor on and drive the camshaft to the proper location. Replace the control. Replace the control. Replace the control.	
Err3	Improper finish of regeneration (limit s itch open hen it should be closed).	Valve camshaft has been manuall rotated out of regeneration complete" position. Fault motor. Fault motor drive. Fault s itch.	The control ill turn the motor on and drive the camshaft to the proper location. Replace the control. Replace the control. Replace the control.	
Err4	Improper control settings (one or more settings out of the allo able range).	One or more settings out of the allo able range.	Hardness: Adjust range: 3 to 250. Capacit: Adjust range: 0.1 to 140.0. Refill control: Adjust range: 1 to 99. Brine dra value: Adjust range per Table 4.1.	

Problem	Possible Cause	Solution		
Capacit displa sta s at 9999 even through there is ater usage.	Total s stem capacit as calculated to be a value greater than 9999.	a. As the ater usage continues, the remaining capacit ill drop belo 9999 and then other values ill be sho n.		
Timer beeps hen left arro button is pressed.	Button is onl active in the programming mode.	a. Refer to the Programming section.		
Timer does not respond to REGEN button.	Button is not active in the programming mode.	Refer to the Regeneration section.		
4. Timer does not displa time of	a. Transformer is unplugged.	a. Connect po er.		
da .	b. No electric po er at outlet.	b. Repair outlet or use orking outlet.		
	c. Defective transformer.	c. Replace transformer.		
	d. Defective circuit board.	d. Replace control.		
5. Timer does not displa correct	a. Outlet operated b as itch.	a. Use outlet not controlled b s itch.		
time of da .	b. Po er outages.	b. Reset Time of Da .		

Problem	Possible Cause		Solution		
6. No ater flo displa hen	a.	B pass valve in b pass position.	a.	Shift b pass valve into service position.	
ater is flo ing (colon does not blink).	b.	Meter probe disconnected or not full connected to meter housing.	b.	Full insert probe into meter housing.	
	C.	Restricted meter turbine rotation due to foreign material in meter!	C.	Remove meter housing, free up turbine and flush ith clean ater. Turbine should spin freel . If not, refer to the Water Meter Maintenance section.	
	d.	Defective meter probe.	d.	Replace control.	
	e.	Defective circuit board.	e.	Replace control.	
7. Control displa is frozen at Regen Time Remaining.	a.	Back to back regenerations ere requested.	a.	Refer to the Manual Regeneration section.	
8. Control regenerates at the	a.	Po er outages.	a.	Reset time of da to correct time of da .	
rong time of da .	b.	Time of da set incorrectl.	b.	Reset time of da to correct time of da .	
	C.	Time of regeneration set incorrectl.	c.	Reset time of regeneration.	
9. Timer stalled in regeneration	a.	Motor not operating.	a.	Replace control.	
c cle.	b.	Motor runs back ards.	b.	Replace control.	
	C.	No electric po er at outlet.	C.	Repair outlet or use orking outlet.	
	d.	Incorrect voltage or frequenc (Hz).	d.	Replace timer and/or transformer ith one of correct voltage and frequenc (Hz).	
	e.	Broken gear.	e.	Replace control.	
	f.	Defective s itch.	f.	Replace control.	
	g.	Air leak in brine connections (pressure locked flapper).	g.	Check all junction points and make appropriate corrections.	
	h.	Binding of camshaft.	h.	Remove foreign object obstruction from valve discs or camshaft.	
	i.	Water pressure greater than 125 psi during regeneration.	i.	Install pressure regulator to reduce pressure.	
	j.	Defective circuit board.	j.	Replace control.	
10. Continuous regeneration.	a.	Broken projection on drive gear.	a.	Replace control.	
Camshaft does not stop at the end of regeneration.	b.	Defective s itch.	b.	Replace control.	
11. Control does not regenerate	a.	Transformer unplugged.	a.	Connect po er.	
automaticall or hen REGEN	b.	No electric po er at outlet.	b.	Repair outlet or use orking outlet.	
button is depressed.	C.	Defective motor.	C.	Replace control.	
	d.	Broken gear.	d.	Replace control.	
	e.	Binding in gear train.	e.	Replace control.	
	f.	Defective s itch.	f.	Replace control.	
12. Control does not regenerate automaticall but does	a.	If ater flo displa is not operative, refer to item 5 in this table.	a.	Refer to item 5 in this table.	
regenerate hen REGEN button is depressed.	b.	Incorrect hardness and capacit settings.	b.	Set ne control values. Refer to the Programming section.	
	C.	Defective circuit board.	C.	Replace control.	
 Run out of soft ater bet een regenerations. 	a.	Improper regeneration.	a.	Repeat regeneration making certain that correct salt dosage is used.	
	b.	Fouled resin bed.	b.	Use resin cleaner.	
	C.	Incorrect salt setting.	C.	Set salt control to proper level. Refer to the Programming section in this manual.	
	d.	Incorrect hardness or capacit settings.	d.	Set to correct values. Refer to the Programming section in this manual.	
	e.	Water hardness has increased.	e.	Set to ne value. Refer to the Programming section in this manual.	
	f.	Restricted meter turbine rotation due to foreign material in meter housing!	f.	Remove meter housing, free up turbine, and flush ith clean ater. Turbine should spin freel , if not, replace meter.	
	g.	E cessive ater usage belo 1/5 gallon per minute.	g.	Repair leak plumbing and/or fi tures.	

Cv Parts

t Exploded View

6.3 Performa Cv Controls

